

Certificate of Compliance

Certificate Number **20100726-EX15510**
Report Reference **EX15510, 2010 July 22**
Issue Date **2010 July 26**

Page 1 of 2



Issued to: **ADVANCE VALVES GLOBAL**

142 A & B NOIDA SPECIAL ECONOMIC ZONE,
PH-II, NOIDA UP 201305 INDIA

*This is to certify that
representative samples of* **Butterfly Valves**


Refer to Addendum page

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: The basic standards used to investigate products in this category are UL 1091
Standard for Butterfly Valves for Fire Protection Service Sixth Edition revision May 12, 2010

Additional Information: See UL On-Line Certification Directory at www.UL.com for additional
Information. With Alternate Listee File no: EX15777

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney,
Director of the North American Certification Program.
Underwriters Laboratories Inc.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd

Certificate of Compliance

Certificate Number **20100726-EX15510**
Report Reference **EX15510, 2010 July 22**
Issue Date **2010 July 26**

Page 2 of 2



This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Size, NPS	Body Type	Pressure Rating, psig (Bar)	Indicator Post	Supervisory Switch*
Butterfly valve					
AV-BF-11	3, 4, 6, 8, 10, 12	Wafer	175	—	—
AV-BF-11	14, 16, 18	Wafer	150	—	—
AV-BF-21	3, 4, 6, 8, 10, 12	Lug	175	—	—
AV-BF-21	14, 16, 18	Lug	150	—	—

* I = Indoor installation; O = Outdoor installation

William R. Carney,
Director of the North American Certification Program.
Underwriters Laboratories Inc.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd